

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-1288:168 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** Gamewell, 12 Clintonville Rd, Northford, CT 06472  
Contact: Brian Reynolds (203) 484-6124 Fax (203) 484-7309

**DESIGN:** Model SS-I ionization smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as an ionization smoke detector for use with listee's listed Models BX501, B610LP, B612LP, B614LP, B616LP or B710LP bases (CSFM Listing No. 7300-0028:173) and separately listed compatible fire alarm control units. Suitable for open area protection at air velocities up to 1200 fpm. Refer to listee's Installation Instruction Manual for details.

**XLF:** 7271-0028:201

07-08-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 8, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager